

WASTEWATER DEPARTMENT REPORT

January 12, 2015

Prepared by Dan Protivansky

ACCOMPLISHMENTS:

- Adjusted air lines in the lagoons to compensate for cold weather and ice.
- Repaired loose aerators and fittings in the lagoon
- Exercised all air line valves at the lagoons
- Organizing department tools, fittings, and inventory
- Exercised check valves at the sewer pumps stations
- Added Degreaser to the wet wells at Columbian Ave and Willow St. We also cleaned all floats and transducers
- Responded to an alarm at the Park pumps station on the 31st.
- Qc services was here on the 5th to do annual calibrations of all our lab testing equipment
- All December monthly state reporting forms complete
- All December monthly sampling requirements complete
- Working with Dan Lilly to install all new ballasts in our back up UV panel at the WWTF
- Changed chemical feed tubing on pump 1 in the Alum injection building. We also cleaned and flushed out tank B and cleaned and flushed all plastic feed lines.
- Cleaned lights in the UV building.
- Drained and cleaned channel near the effluent weir
- Exercised the clay valve on the discharge line at the WWTF

IN PROGRESS:

- Brush cutting around the fence at the WWTF
- Preparing a work list for spring/summer projects
- Working on budgets with Stan