

# **WATER DEPARTMENT REPORT**

January 12, 2015

Prepared by Dan Protivansky

## **ACCOMPLISHMENTS:**

- Drained all internal plumbing at the Chittenden water plant. Shut off Furnace. Cut and capped the 6 inch raw water main. We still have 2 more cut and caps to do.
- Field St well is running great. We have had no issues. Jon Champlin has been here to fine tune all the scada equipment. On average we are pumping around 150,000 gallons a day at the new Well. We were doing 400,000 a day from the Chittenden water plant.
- Scheduled with Linda Greaves from the Department of Health for her to come down and help us set up and turn on the Fluoride feed system
- Scheduled with the Water Supply Division to come down and help us with the Stage 2 DBP Compliance Monitoring Plan.
- Discovered a small water leak on High St near the 5 corners. We are working with VRWA to pin point where the leak is and we will schedule a day to dig and repair.
- Attended a close out meeting with Tom Doty
- Completed all December state reporting forms
- Completed all December monthly sampling requirements
- Located a curb stop for a customer on Ormsbee Ave
- Worked with Stan doing invoices and budgeting
- Dug out the swale on High St so the water from the leak doesn't effect the road
- Weekly monitoring of pressure, Ph, and chlorine residuals in the distribution system

## **IN PROGRESS:**

- Working with Stan on making a daily operations form
- Cut and cap the 6 inch finished water main in Chittenden
- Clean up at the Filter plant in Chittenden