

# WASTEWATER DEPARTMENT REPORT

January 26, 2015

Prepared by Dan Protivansky

## ACCOMPLISHMENTS:

- Started cutting the brush around the WWTF fence
- Worked with Stan doing a daily, weekly, and monthly operations form
- Worked with the HW Dept plowing and doing sidewalks
- Completed all January required monthly sampling
- Ordered parts to change the pressure reducing valve at the WWTF. The pressure relief valve keeps tripping on the hot water heater. The existing PRV is old and we can not adjust it
- Ordered 3000 gallons of Alum for the WWTF. It will be delivered Tuesday the 27<sup>th</sup>
- Used the HW truck to sand all buildings and access roads due to all the ice
- Organized files and cleaned the WWTF office
- Started organizing and cleaning in the blower building. This fall we brought down all the water/sewer equipment from the garage to make more room for the jetter

## IN PROGRESS:

- Brush cutting around the fence at the WWTF
- Blower building cleaning
- Change oil and clean lobes on all 3 blowers
- Replace exhaust fan bearings in the blower building
- Remove old level indicator and floats at Columbian Ave pump station
- Replace PRV at the WWTF office when parts arrive
- Clean grease from the wet wells at Columbian Ave and Willow St pump stations. We do this a lot to avoid any problems. For some reason these stations accumulate a lot of grease