

## **WASTEWATER DEPARTMENT REPORT**

July 14, 2014

### **ACCOMPLISHMENTS:**

- Daily operations and maintenance
- Completed all monthly state reporting for June
- Worked with the HW DEPT on the storm water project on Pleasant St
- Replaced all the chemical feed lines inside the phosphorous removal building

### **IN PROGRESS:**

- Sewer line flushing throughout the town
- Build storage shelves at the WWTF
- Re-brick manhole in the library parking lot
- Working with our engineer on the transfer manhole project
- Replacing bearings on our exhaust fans in the blower building
- Working with Dan Lilly correcting a problem with a VFD in the blower building.
- Repairing a few broken air lines in lagoon # 1
- Servicing the sewer Jetter
- Sampling for E. Coli in a few spots where the State has expected possible cross connections between the sewer and storm water systems
- Remove a pump at styles meadow due to a seal fail. Pump is still working right now. We will send the old one out for rebuild