

WATER DEPARTMENT REPORT

JULY 14, 2014

ACCOMPLISHMENTS:

- Daily operations and maintenance
- Installed a new raw water “smart valve” at the Filter Plant. The old one stopped working due to electrical problem
- Worked with the HW DEPT on the storm water project on Pleasant St
- Worked with Stan reissuing boil water notices in the outer district
- Took 8 total coliform samples on the west side of town to lift the boil water notice due to the west side tank tie in.
- Climbing the west side tank daily to check the level until power is restored to our level control.
- Completed all state reporting forms for June
- Sampled the pool for E. Coli. So far all the samples have been good.
- Due to the recent issues at the filter plant we had to do a lot of flushing on the east side of town to remove air from the system, so we are almost complete with our summer flushing. The same goes for the west side, after the tie in Belden did at the tank we flushed a lot of the system on the west side.
-

IN PROGRESS:

- Preparing to do 10 Lead and copper samples in the distribution system.
- Scheduling a meeting with Stan and the Water Supply Division to discuss disinfection byproducts
- Repairing a valve box at the elementary school
- Repairing a valve box in the Omya parking lot and one on the corner of Maple and Oak St

- Scheduling with the generator company to have all our generators serviced
- Received a complaint from Green Mountain Power about a color and odor problem from a storm water discharge near the power station. We are planning on doing some dye testing in the area to try and figure out what is going on