

WATER DEPARTMENT REPORT

July 28, 2014

ACCOMPLISHMENTS:

- Daily operations and maintenance
- Mowed and trimmed the grass at Field St Well
- Responded to a low water pressure complaint on Park St. Ended up being a homeowner issue
- All monthly samples complete for July
- Cleaned, primed, and painted the vents and covers on the isolation valve vaults on South Street
- Weekly E Coil samples at the Pool. We sample every Monday morning. So far ALL the samples have been good
- Started flushing and cleaning at the Furnace Brook Intake. We want it to be ready to go incase we get too low at Kiln Brook
- Replaced chemical feed tubing and rebuilt our main Chlorine pump at the Filter Plant
- Assisted the HW Dept with ditch work on Gorham Bridge Road and helped them with a storm water issue on School St
- Traced out water utilities on Willow St. GMP is replacing 2 poles on that street
- Traced out utilities on School St for HW Dept storm water project
- Traced out our water transmission main near Taranovich for their upcoming project

IN PROGRESS:

- Preparing to do 10 lead and copper samples in the distribution system
- Meeting with Water Supply Division and Stan is scheduled for Monday July 28th at 10am to discuss disinfection byproducts
- Repair a valve box at the Elementary School and Oak St
- Called VT Rural Water to get help identifying a possible cross connection in the marble yard