

# **WATER DEPARTMENT REPORT**

August 25, 2013

## **ACCOMPLISHMENTS:**

- Daily operations and maintenance
- Worked with the HW Dept on Pine St replacing a storm drain and pipe work.
- Completed all July monthly reporting forms
- Completed all required sampling for August
- Weekly Pool samples complete. Pool is now closed. We are in the Process of draining it slowly and the building has been drained and winterized
- Worked with Belden replacing a valve on School and High St
- Repaired a safety fence around a pool located at 72 West St
- Meet with Belden to get an estimate on replacing 2 valves on School St and 1 valve on North St
- Started handing out lead and copper sample bottles for collection. These tests require that the homeowner takes the sample and then leaves it outside for us to collect the following day.
- Mowed and trimmed at the Field St Well
- Exercised a valve on North St. We were able to stop it from leaking for now.
- Repaired perimeter drain at the Well
- Repaired broken valve box on Oak St

## **IN PROGRESS:**

- Draining of the Proctor Pool
- Well start up and a plan to cut and cap the transmission main from Chittenden water plant.

## **NEEDED:**

- Permission from the board to purchase supplies and stain for Cain St Booster Pump Station and color preference
- Permission from the board to contact our electrician to fix the ground wire at Kiln Brook Intake. Someone cut and stole about 4 feet of it.
- Have identified poorly operating valves at 5 corners, School St at Taylor Hill, and old west side tank isolation valve. We need direction from the board to move forward repairing or replacing.

