

WASTEWATER DEPARTMENT REPORT

September 8, 2014

ACCOMPLISHMENTS:

- Drained the lagoons down 2 feet for the pipe repair job at the WWTF
- Working with Belden and our engineer on the lagoon transfer manhole project. Leaking and damaged pipe has slowed down the job
- Shut off discharge at the WWTF because the lagoon levels are so low
- Shut off Alum Feed for Phosphorous removal at the WWTF
- Started bypass pumping from lagoon 1 to lagoon 2
- Notified Wastewater Management Division about our current lagoon status