

WASTEWATER DEPARTMENT REPORT

September 22, 2014

ACCOMPLISHMENTS:

- Cleaned and organized the WWTF lab and back storage room.
- Meet with Wayne Elliot on the 8th to discuss our pipe problems at the WWTF.
- Used 2 pumps to pump from lagoon 1 to lagoon 2 while the plant was shut down during construction.
- Belden completed the transfer manhole project. We pulled the 2 plugs from lagoon 2 and are now back to normal operating level. We are back to injecting Alum at the transfer manhole and we are back to discharging effluent to the creek
- Picked up and cleaned all pumps, plugs, and other equipment used during the construction project.
- Cleaned the isolation valve and cleaned around the weir before we started discharging.
- Saved all the old pipe from the construction job. Wayne Elliott wants to send out pipe samples to try and figure out what happened.
- August monthly reporting forms complete.
- Routine sewer cleaning on Main St and the marble yard. We have a list of troubled areas that we will clean before winter.

IN PROGRESS:

- Continue with routine sewer flushing.
- Getting quotes to have the new bumper crane installed on the F350
- Building shelves at the WWTF