

WASTEWATER DEPARTMENT REPORT

October 27, 2014

ACCOMPLISHMENTS:

- Added gravel and graded around the alum injection manhole at the WWTF
- Meet with John J and Warren so they could inspect sewer manholes near the Omya building on Main St
- Cleaned both UV disinfection light chambers at the WWTF
- Completed all monthly required sampling
- Completed all September monthly operating forms
- Wayne Elliott here to collect pipe from the lagoon transfer manhole project. He is sending it out to be evaluated by the pipe company to try and figure out what happened.

IN PROGRESS:

- Replacing guard rail posts around the lagoons
- Winterizing all building and pump stations
- Storing the lagoon boat for the winter
- Repairing a few leaks on the aeration system at the WWTF

NEEDED:

- Need Selectboard approval to purchase ballasts for the UV disinfection system. See attached quote
- Does the Selectboard want us getting quotes to purchase a new sign at the entrance of the WWTF?