

WATER DEPARTMENT REPORT
November 24, 2014

ACCOMPLISHMENTS:

- Worked with Belden fixing a leak in the Marble yard. This was the marble company's private line and we assisted in shutting our mains down while the repair was made. Our west side tank is back to its normal operating level.
- Worked with a homeowner on South St to fix a water service. We had to shut down our main so the repair could be done.
- Worked with Jon Champlin at the South St valve vault. We still have a few bugs to work out but we are sending water through the vault now
- Completed all monthly sampling requirements for November, including stage 2 disinfection by products
- Sampled the Field St Well for natural fluoride
- Bumper crane is installed on the F350
- Worked with Aaron Perez from VRWA looking at different leak detection equipment.
- Scheduled with VRWA to have Aaron here during Field St well start up/ Filter plant shutdown so we have a little more help that day
- Shut off the water service at the youth league fields
- Talked with the tank company about fixing our overflow pipe at the west side tank. I sent him pictures and he will be getting back to me about repair solutions.
- Completed all October monthly reports
- Working with Aaron from VRWA to post equipment on VRWA website classified section. Once the filter plant is shut down we will have a lot of equipment we won't need anymore

IN PROGRESS:

- Working with the HW Dept to lower valves on School St sidewalk