

WATER DEPARTMENT REPORT

December 8, 2014

ACCOMPLISHMENTS:

- Lowered 2 valve boxes on School Street
- Installed a heater in the pressure reducing vault on Field St
- Repairs made to plow frame on the F350
- Attended construction meeting on the 26th
- Traced out the water main on Polli's property for insertion valve job
- Picked up chlorine from Allen's for the Filter Plant
- Exercised valves at the intakes and water filter plant for upcoming shut down
- Sampled for Total Coliform at the new East side tank and Field St Well. All samples Negative.
- Continuous tank level checks and valve adjustments as needed during the weekends
- Completed a water shut off on Powers Square for a customer
- Ordered new leak detection equipment. Should be here in a few weeks
- Contacted the tank company to have our overflow pipe repaired at the West side tank. They gave us two options, one is to hire a local welding company do the work and the other option is to have them come out and repair. They will be submitting a quote to perform the work.
- Spoke with Dave Eves about East tank leakage test, All results have been documented
- Wet tap valve installed at Polli's property on route 3