

PROCTOR WATER DEPARTMENT REPORT

December 22, 2014

ACCOMPLISHMENTS:

- Shut down the Intake and Filter Plant in Chittenden on December 8th. Ran the system off of tank pressure and volume for the day.
- Started up the old pump at Field St well on Tuesday December 9th.
- Worked with the Clay Valve representative to calibrate all valves in the new system. So far everything seems to be working properly.
- Insertion valve installed near the town line was completed on the 8th. Kingsbury cut and capped the 6 inch transmission main from Chittenden on the 15th.
- Drained transmission main from Chittenden at the blow off near Stevens road.
- Worked with Jon Champlin on set points, tank levels, chlorine pump calibration Scada equipment etc at Field St Well.
- Monitored pressure at various locations in the distribution system during Well Start up
- Kingsbury cut and capped old piping to the old east side tank. We are in the process of slowly draining the tank now
- Completed all required monthly sampling.
- Completed all November monthly reporting forms
- Traced utilities on Park St for customer. Located curb stop for customer so plumber could fix a leak inside the house.