

PROCTOR WASTEWATER DEPARTMENT REPORT

December 22, 2014

ACCOMPLISHMENTS:

- Cleaned UV unit 2 and T valve.
- All December monthly sampling requirements complete
- All November state reporting forms complete
- Changed Tubing on Alum pump number 2
- Responded to a customer complaint on Gibbs St. Opened manholes and confirmed our main was free flowing. Homeowner calling plumber to get their line fixed.